


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/NDZ/2021/ 628

Dated:- 23/08/2021

FIRE SAFETY CERTIFICATE

Certified that the Salwan Public School located at Mayur Vihar Ph-III, Delhi-96 comprised of Ground + 04 Upper floors, owned/occupied by Salwan Public School, was granted FSC by this department vide letter No. F6/DFS/MS/2018/NDZ/302 dated 26/02/2018. The premises was re-inspected by the officer concerned of this department on 03/08/2021 in the presence of the Mr. A.K Tyagi & Mr. Manoj Verma (Estate Officer) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "B" 'Educational Building' Ground + 04 Upper floors only with effect from 23/08/2021 for a period of three years, subject to conditions, printed below.
Issued on 23/08/2021 at New Delhi by.



(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education,
D-Block, Anand Vihar, Delhi-91.
2. The Principal,
Salwan Public School, Mayur Vihar Ph-III, Delhi-96.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be used in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'K' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".


Principal
Salwan Public School
Mayur Vihar Phase-III,
Delhi-110096


Director
Salwan Public School
Kondli Gharouli Complex
Mayur Vihar Phase-III,
Delhi-110096